

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016062.03
DATE: 02/26/2024
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Premium Clad" Aluminum Clad Wood Outswing French Side Hinged Door (w/Transom) Configuration: O/XX Glazing: Insulating Glass (Tempered) Transom (Annealed Glass) Frame: W-2217mm(87.28") H-3115mm(122.64") Panel: W-1066mm(41.97") H-2437mm(95.94") DLO: W-820mm(32.28") H-2160mm(85.04")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class LC-PG35 2217 x 3115 (87 x 123)-SHD Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.25 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: National Certified Testing Laboratories
Report No: SJW2014-091/SJW2014-056/SJW2014-053
Expiration Date: **February 28, 2028**

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com