

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016062.05  
DATE: 02/26/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: JELD-WEN  
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Series "Premium Wood"</b> <b>Aluminum Clad Wood</b> <b>Outswing French Side Hinged Door</b>  Configuration: XX Glazing: Insulating Glass (Tempered) Frame: W-1911mm(75.25") H-2502mm(98.50") Panel: W-912mm(35.91") H-2439mm(96.02") DLO: W-665mm(26.18") H-2162mm(85.12")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>CSA A440S1-09</b>	<b>Class LC-PG50 1911 x 2502 (75 x 99)-SHD</b> <b>Design Pressure: ±2400 Pa (±50 psf)</b> <b>Water Penetration Resistance Test Pressure: 360 Pa (7.50 psf)</b> <b>Canadian Air Infiltration/Exfiltration Level: A3</b>

Product Tested By: National Certified Testing Laboratories  
Report No: SJW2014-102/SJW2014-056  
Expiration Date: **February 28, 2028**

Administrator's Signature: \_\_\_\_\_ 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023