

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016062.08
DATE: 02/26/2024
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Siteline Clad Narrow Stile French Door" Aluminum Clad Wood Outswing French Side Hinged Door Configuration: XX Glazing: Insulating Glass (Tempered) Frame: W-1810mm(71.26") H-2502mm(98.50") Panel: W-863mm(33.98") H-2440mm(96.06") DLO: W-680mm(26.77") H-2150mm(84.65")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class LC-PG35 1810 x 2502 (71 x 99)-SHD Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: National Certified Testing Laboratories
Report No: SJW2014-122/SJW2014-123
Expiration Date: **February 28, 2028**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023