

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016062.11  
DATE: 02/26/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: JELD-WEN  
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b>  <b>3737 Lakeport Boulevard</b>  <b>Klamath Falls, OR 97601</b>	<b>Series "Siteline or W-4500 Wood"</b>  <b>Wood Outswing French Side Hinged Door</b>  Configuration: XX Glazing: Insulating Glass (Tempered) Frame: W-1911mm(75.25") H-2425mm(95.47") Panel: W-912mm(35.91") H-2364mm(93.07") DLO: W-665mm(26.18") H-2025mm(79.72")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>CSA A440S1-09</b>	<b>Class LC-PG50 1911 x 2425 (75 x 95)-SHD</b> <b>Design Pressure: ±2400 Pa (±50 psf)</b> Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: National Certified Testing Laboratories  
Report No: SJW2015-062/SJW2014-092  
Expiration Date: **February 28, 2028**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023