## **NOTICE OF PRODUCT CERTIFICATION**



CERTIFICATION NO: NI016063.03

**DATE:** 02/27/2024

**CERTIFICATION PROGRAM:** Structural

**COMPANY: JELD-WEN** 

**CODE:** 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <a href="www.namicertification.com">www.namicertification.com</a>. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS		PRODUCT DESC	CRIPTION
JELD-WEN	Series "Premium Clad Outswing Door -		
3737 Lakeport Boulevard	Fixed Panel"		
Klamath Falls, OR 97601	Aluminum Clad Wood Fixed Door		
		Configuration	n: O
		Glazing: Insulating Gla	ss (Tempered)
	Frame:	W-1110mm(43.70")	H-2502mm(98.50")
	Panel:	W-1067mm(42.01")	H-2442mm(96.14")
	DLO:	W-937mm(36.90")	H-2162mm(85.12")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class LC-PG35 1110 x 2502 (44 x 99)-FD  Design Pressure: ±1680 Pa (±35 psf)  Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)  Canadian Air Infiltration/Exfiltration Level: Fixed

Product Tested By: National Certified Testing Laboratories

Report No: SJW2014-055
Expiration Date: **February 28, 2028** 

Administrator's Signature:

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072

Tel: (804) 684-5124 Email: nami@namiinc.com