

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016063.06
DATE: 02/27/2024
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|--|
| JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601 | Series "Premium Wood" Wood Outswing Side Hinged Door Configuration: OX Glazing: Insulating Glass (Tempered) Frame: W-1911mm(75.25") H-2502mm(98.50") Panel: W-919mm(36.18") H-2165mm(85.24") DLO: W-785mm(30.91") H-2165mm(85.24") |

| SPECIFICATION | PRODUCT RATING |
|--|---|
| AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09 | Class LC-PG50 1911 x 2502 (75 x 99)-SHD Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.50 psf) Canadian Air Infiltration/Exfiltration Level: A3 |

Product Tested By: National Certified Testing Laboratories
Report No: SJW2014-101/SJW2014-096
Expiration Date: **February 28, 2028**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com