

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016063
DATE: 02/27/2024
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Siteline Clad" Aluminum Clad Wood Outswing Side Hinged Door Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-956mm(37.63") H-3035mm(119.50") Panel: W-914mm(36") H-2972mm(117") DLO: W-692mm(27.25") H-2615mm(102.94")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class LC-PG35 956 x 3035 (38 x 120)-SHD Design Pressure: 1680 Pa (35 psf) Positive Design Pressure: 1680 Pa (35 psf) Negative Design Pressure: 1920 Pa (40 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Element Materials Technology
Report No: ESP025820P-2185.16
Expiration Date: **February 28, 2028**

Administrator's Signature:  _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com