

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016064  
DATE: 02/27/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: JELD-WEN  
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Series "Premium Clad"</b> <b>Aluminum Clad Wood</b> <b>Outswing Fixed Transom</b>  Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-2217mm(87.28") H-609mm(23.98") Panel: W-2173mm(85.55") H-567mm(22.32") DLO: W-2045mm(80.51") H-440mm(17.32")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>CSA A440S1-09</b>	<b>Class LC-PG35 2217 x 609 (87 x 24)-TR</b> <b>Design Pressure: ±1680 Pa (±35 psf)</b> <b>Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)</b> <b>Canadian Air Infiltration/Exfiltration Level: Fixed</b>

Product Tested By: National Certified Testing Laboratories  
Report No: SJW2014-053  
Expiration Date: **February 28, 2028**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)