

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016066.01
DATE: 02/27/2024
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Premium Sitrine EX Wood" Wood Horizontal Sliding Window Configuration: XX Glazing: Insulating Glass (Annealed) Frame: W-1813mm(71.38") H-1511mm(59.50") Sash: W-899mm(35.38") H-1434mm(56.44") DLO: W-806mm(31.75") H-1346mm(53")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG30 1813 x 1511 (71 x 60)-HS Design Pressure: ±1440 Pa (±30 psf) Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf)

Product Tested By: National Certified Testing Laboratories
Report No: SJW2013-059
Expiration Date: **February 28, 2028**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023