

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016069
DATE: 02/29/2024
CERTIFICATION PROGRAM: Structural
COMPANY: AWILUX
CODE: 2961-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
AWILUX Polska Sp. zo.o. Sp.k. ul. Budowlanych 9 PL 64-100 Leszno, Poland	Series "CP155 Lift & Slide" Lift & Slide Aluminum Sliding Door (3 Track, 2 Track & Monorail Frame) Configuration: XXXO or XO Glazing: IG-1/4" Heat Strengthened Glass/0.090" SentryGlas Plus Interlayer/1/4" Heat Strengthened Glass Frame: W-7350mm(289.37") H-3050mm(120.08") Panel: W-1863mm(73.35") H-2936mm(115.59") DLO: W-1646mm(64.80") H-2732mm(107.56")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94 ASTM E283-04 ASTM E331-00	Design Pressure: +65/-65 psf 3-Track Frame: Water Penetration Resistance Test Pressure: 470 Pa (9.82 psf) 2-Track & Monorail Frame: Water Penetration Resistance Test Pressure: 580 Pa (12.00 psf) Large Missile Impact Rated

Product Tested By: Blackwater Testing Lab
Report No: BW-RNV-20-001
Expiration Date: **January 31, 2028**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023