NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: DATE: CERTIFICATION PROGRAM: COMPANY: CODE:

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com.</u> NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | | PRODUCT DESC | CRIPTION |
|-----------------------------------|---|------------------|------------------|
| Comfort View Products, LLC | Series "1900" | | |
| 320 Coweta Industrial Park | Vinyl Twin Single Hung Window | | |
| Building 7, Suite C-1 | | | |
| Newnan, GA 30265 | Configuration: O/XO/X Glazing: Insulating Glass (Annealed) | | |
| | Frame: | W-1815mm(71.46") | H-2120mm(83.47") |
| | Sash: | W-825mm(32.48") | H-1035mm(40.75") |
| | DLO: | W-760mm(29.92") | H-968mm(38.11") |

| SPECIFICATION | PRODUCT RATING | |
|--|---|--|
| AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 | Class R-PG50 1815 x 2120 (71 x 83)-H Design Pressure: ±2400 Pa (±50 psf)) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) | |
| Product Tested By: National Certified Testing Laboratories | | |

Report No: Expiration Date: National Certified Testing NCTL-110-18370-1 February 28, 2026

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072

Tel: (804) 684-5124 Email: nami@namiinc.com

NOPC-03/30/2023