NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: DATE: CERTIFICATION PROGRAM: COMPANY: CODE:

NI016070.03
02/28/2024
Structural
Comfort View
2111-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com.</u> NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS		PRODUCT DESC	CRIPTION
Comfort View Products, LLC		Series "19	00''
320 Coweta Industrial Park	V	inyl Twin Single H	ung Window
Building 7, Suite C-1		(w/1901 Tran	isom)
Newnan, GA 30265			
		Configuration: O/ Glazing: Insulating Gla	
	Frame:	W-1819mm(71.61")	H-2733mm(107.59")
	Sash:	W-828mm(32.59")	H-886mm(34.88")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG50 1819 x 2733 (72 x 108)-H
	Design Pressure: ±2400 Pa (±50 psf)) Water Penetration Resistance Test Pressure: 360 Pa (7.50 psf)
	Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Report No: Expiration Date: AIR-INS, Inc. AI-03658-A1 **February 28, 2026**

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072 Tel: (804) 684-5124 Email: nami@namiinc.com

NOPC-03/30/2023