

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016071
DATE: 02/28/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Comfort View
CODE: 2111-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Comfort View Products, LLC 320 Coweta Industrial Park Building 7, Suite C-1 Newnan, GA 30265	Series "1900" Vinyl Single Hung Window Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1118mm(44") H-1829mm(72") Sash: W-1041mm(41") H-889mm(35") DLO W-997mm(39.25") H-826mm(32.50")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class R-PG45 1118 x 1829 (44 x 72)-H H-R45 1118 x 1829 (44 x 72) Design Pressure: ±2160 Pa (±45 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Architectural Testing, Inc.
Report No: 90640.02-602-44
Expiration Date: **February 28, 2026**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com