

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014586.01  
DATE: 03/20/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: Coeur D'Alene  
CODE: 1654-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Coeur D'Alene Window Company, LLC</b> <b>115 N. Sycamore Street</b> <b>Spokane, WA 99202</b>	<b>Series "6121"</b> <b>Vinyl Horizontal Sliding Window</b>  Configuration: XO Glazing: Insulating Glass (Annealed)  Frame: W-1829mm(72")      H-1524mm(60") Sash: W-899mm(35.38")      H-1451mm(57.13") DLO: W-810mm(31.88")      H-1365mm(53.75")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class LC-PG40 1829 x 1524 (72 x 60)-HS</b> <b>Design Pressure: ±1920 Pa (±40 psf)</b> Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf) <b>Canadian Air Infiltration/Exfiltration Level: A2</b>

Product Tested By: Intertek, PLC  
Report No: P2113.01-901-44  
Expiration Date: **Janaury 31, 2028**

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "S.M.D.", written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)