

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015763.01
DATE: 03/21/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Hoelscher
CODE: 1765-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Hoelscher Weatherstrip Manufacturing Company, Inc. 10111 Houston Oaks Drive Houston, TX 77064	Series "HWS 3680" Glazed 5 Lite Fiberglass Inswing Side-Hinged Door Configuration: X Glazing: Insulated Glass (Tempered) Frame: W-1105mm(43.50") H-2483mm(97.75") Panel: W-1060mm(41.75") H-2419mm(95.25") DLO: W-781mm(30.75") H-292mm(11.50")

SPECIFICATION	PRODUCT RATING
ASTM E330/E330M-14	DP: +45/-45 psf

Product Tested By: Intertek, PLC
Report No: R0605.01-801-44
Expiration Date: **February 28, 2028**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023