

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015963.01
DATE: 03/18/2024
CERTIFICATION PROGRAM: Structural
COMPANY: MAISON JAN
CODE: 2883-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Maison Janneau, LLC 5555 N Lamar Blvd., Suite L125 Austin, Texas 78751	Series "TRADI - LAFAYETTE Wood Awning Window Configuration: X Glazing: IG-Ext. 5/32" Tempered Glass/0.080 PVB Interlayer/5/32" Tempered Glass/Int. 5/32" Annealed Glass Frame: W-1200mm(47.25") H-800mm(31.50") Vent: W-1149mm(45.25") H-743mm(29.25") DLO: W-1010mm(39.75") H-591mm(23.25")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±2880 Pa (±60 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.20 psf) Large Missile Impact Rated

Product Tested By: Molimo, LLC
Report No: 12442.02-106-11
Expiration Date: November 30, 2027

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com