

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016070.05  
DATE: 03/04/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: Comfort View  
CODE: 2111-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS  | PRODUCT DESCRIPTION  |
|---|--|
| <b>Comfort View Products, LLC</b><br><b>320 Coweta Industrial Park</b><br><b>Building 7, Suite C-1</b><br><b>Newnan, GA 30265</b> | <b>Series "1900 HP"</b><br><b>Vinyl Single Hung Window</b><br><br>Configuration: O/X<br>Glazing: Insulating Glass (Annealed)<br>Frame: W-899mm(35.38") H-1816mm(71.50")<br>Sash: W-826mm(32.50") H-883mm(34.75")<br>DLO: W-781mm(30.75") H-819mm(32.25") |

| SPECIFICATION  | PRODUCT RATING   |
|--|--|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b> | <b>Class R-PG50 899 x 1816* (36 x 72*)-H</b><br><b>H-R50 899 x 1816* (36 x 72*)</b><br><b>Design Pressure: ±2400 Pa (±50 psf)</b><br>Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) |

Product Tested By: Architectural Testing, Inc.  
Report No: 93310.01-602-44/90640.02-602-44  
Expiration Date: **February 28, 2026**

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)