

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016074  
DATE: 03/04/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: Comfort View  
CODE: 2111-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Comfort View Products, LLC</b> <b>320 Coweta Industrial Park</b> <b>Building 7, Suite C-1</b> <b>Newnan, GA 30265</b>	<b>Series "1901 Picture Window"</b> <b>Vinyl Fixed Window</b>  Configuration: O Glazing: Insulating Glass (Annealed)  Frame: W-1219mm(48") H-1829mm(72") DLO: W-1099mm(43.25") H-1708mm(67.25")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b>	<b>Class R-PG50 1219 x 1829 (48 x 72)-FW</b> <b>FW-R50 1219 x 1829 (48 x 72)</b> <b>Design Pressure: ±2400 Pa (±50 psf)</b> <b>Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)</b>

Product Tested By: Architectural Testing, Inc.  
Report No: 90643.01-602-44  
Expiration Date: **February 28, 2026**

Administrator's Signature: \_\_\_\_\_ 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)