NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI016075.05-R1**
DATE:	**03/04/2024**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Comfort View**
CODE:	**2111-1**
REVISION DATE:	**01/22/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Comfort View Products, LLC **320 Coweta Industrial Park** **Building 7, Suite C-1** **Newnan, GA 30265**	**Series "1500"** **Vinyl Outswing Casement Window** Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-610mm(24") H-1524mm(60") Vent: W-546mm(21.50") H-1461mm(57.50") DLO: W-464mm(18.25") H-1378mm(54.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 **AAMA/WDMA/CSA 101/I.S.2/A440-05**	**Class R-PG50 610 x 1524 (24 x 60)-C** **C-R50 610 x 1524 (24 x 60)** **Design Pressure: ±2400 Pa (±50 psf)** **Water Penetration Resistance Test Pressure: 580 Pa (12.12 psf)**

Product Tested By: Intertek, PLC
Report No: C8900.03-501-47
Expiration Date: **February 28, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com