

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI016075.06  
**DATE:** 03/04/2024  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Comfort View  
**CODE:** 2111-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Comfort View Products, LLC</b> <b>320 Coweta Industrial Park</b> <b>Building 7, Suite C-1</b> <b>Newnan, GA 30265</b>	<b>Series "1500"</b> <b>Vinyl Outswing Casement Window</b>  Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-610mm(24") H-1524mm(60") Vent: W-546mm(21.50") H-1461mm(57.50") DLO: W-464mm(18.25") H-1378mm(54.25")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b>	<b>Class R-PG80 610 x 1524 (24 x 60)-C</b> <b>C-R80 610 x 1524 (24 x 60)</b> <b>Design Pressure: <math>\pm 3840</math> Pa (<math>\pm 80</math> psf)</b> <b>Water Penetration Resistance Test Pressure: 580 Pa (12.12 psf)</b>

Product Tested By: Intertek, PLC  
Report No: C8900.03-501-47  
Expiration Date: **February 28, 2026**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023