

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016076.04
DATE: 03/04/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Comfort View
CODE: 2111-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Comfort View Products, LLC 320 Coweta Industrial Park Building 7, Suite C-1 Newnan, GA 30265	Series "1600" Vinyl Awning Window Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-914mm(36") H-610mm(24") Vent: W-851mm(33.50") H-546mm(21.50") DLO: W-768mm(30.25") H-464mm(18.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class LC-PG50 914 x 610* (36 x 24*)-AP AP-LC50 914 x 610* (36 x 24*) Design Pressure: 2400 Pa (50 psf) Positive Design Pressure: 3600 Pa (75 psf) Negative Design Pressure: 3600 Pa (75 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Intertek, PLC
Report No: C8901.03-501-47
Expiration Date: **February 28, 2026**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi D", is written over the signature line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023