

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016076
DATE: 03/04/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Comfort View
CODE: 2111-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Comfort View Products, LLC 320 Coweta Industrial Park Building 7, Suite C-1 Newnan, GA 30265	Series "1600" Vinyl Awning Window Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-1219mm(48") H-813mm(32") Vent: W-1156mm(45.50") H-749mm(29.50") DLO: W-1073mm(42.25") H-667mm(26.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class LC-PG30 1219 x 813 (48 x 32)-AP AP-LC30 1219 x 813 (48 x 32) Design Pressure: ±1440 Pa (±30 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Intertek, PLC
Report No: C8901.03-501-47
Expiration Date: **February 28, 2026**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shirley".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023