

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016080
DATE: 03/06/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Fleetwood
CODE: 1855-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Fleetwood Windows and Doors 1 Fleetwood Way Corona, CA 92879	Series "450-T" Thermally Broken Aluminum Casement Window Configuration: XX Glazing: Insulating Glass (Annealed) Frame: W-1524mm(60") H-1829mm(72") Vent: W-749mm(29.50") H-1816mm(71.50")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 CSA A440S1:19	Class LC PG40 1524 x 1829 (60 x 72)-C Design Pressure: ± 1920 Pa (± 40 psf) Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Fenestration Testing Laboratory, Inc.
Report No: T23-106
Expiration Date: December 31, 2027

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD" or similar, written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023