

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016089.02  
DATE: 03/07/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: Willamette  
CODE: 2992-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Willamette Windows Corporation</b> <b>2800 Pringle Road SE, Suite 120</b> <b>Salem, OR 97209</b>	<b>Series "McKenzie"</b> <b>Vinyl Casement Assembly</b> <b>(w/Fixed Windows)</b> Configuration: X/XX/X Glazing: Insulating Glass (Annealed) Frame: W-1813mm(71.38") H-1813mm(71.38") Sash: W-864mm(34") H-1314mm(51.75") DLO: W-737mm(29") H-1187mm(46.75")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class LC-PG45 1813 x 1813 (71 x 71)-C</b> <b>Design Pressure: ±2160 Pa (±45 psf)</b> Water Penetration Resistance Test Pressure: 440 Pa (9.20 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Intertek, PLC  
Report No: M3003.01-901-44  
Expiration Date: **February 28, 2028**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)