

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016089.05  
DATE: 03/07/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: Willamette  
CODE: 2992-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Willamette Windows Corporation</b> <b>2800 Pringle Road SE, Suite 120</b> <b>Salem, OR 97209</b>	<b>Series "McKenzie"</b> <b>Vinyl Casement Assembly</b> <b>(w/Fixed Window)</b>  Configuration: XX/O Glazing: Insulating Glass (Tempered)  Frame: W-1676mm(66") H-2540mm(100") Sash: W-795mm(31.31") H-1788mm(70.38") DLO: W-664mm(26.13") H-1654mm(65.13")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-22</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class LC-PG35 1676 x 2540 (66 x 100)-C</b> <b>Design Pressure: ±1680 Pa (±35 psf)</b> Water Penetration Resistance Test Pressure: 440 Pa (9.20 psf) <b>Canadian Air Infiltration/Exfiltration Level: A3</b>

Product Tested By: Intertek, PLC  
Report No: Q6455.01-901-44  
Expiration Date: **February 28, 2028**

Administrator's Signature: \_\_\_\_\_ 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)