

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016089.07
DATE: 03/07/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Willamette
CODE: 2992-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Willamette Windows Corporation 2800 Pringle Road SE, Suite 120 Salem, OR 97209	Series "McKenzie CA" Vinyl Outswing Casement Window Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-914mm(36") H-1822mm(71.75") Sash: W-864mm(34") H-1778mm(70") DLO: W-737mm(29") H-1651mm(65")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class LC-PG55 914 x 1822 (36 x 72)-C Design Pressure: 2640 Pa (55 psf) Positive Design Pressure: 2880 Pa (60 psf) Negative Design Pressure: 2640 Pa 55 psf) Water Penetration Resistance Test Pressure: 400 Pa (8.36 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Intertek, PLC
Report No: K7605.02-501-47
Expiration Date: February 28, 2028

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com