

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016089
DATE: 03/07/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Willamette
CODE: 2992-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Willamette Windows Corporation 2800 Pringle Road SE, Suite 120 Salem, OR 97209	Series "326CA - McKenzie" Vinyl Casement Assembly (w/Fixed Windows) Configuration: OOO/XOX Glazing: Insulating Glass (Annealed) Frame: W-2743mm(108") H-2438mm(96") Vent: W-873mm(34.38") H-1483mm(58.38") DLO: W-743mm(29.25") H-1356mm(53.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class LC-PG40 2743 x 2438 (108 x 96)-C Design Pressure: ±1920 Pa (±40 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.12 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Intertek, PLC
Report No: N2633.01-901-44
Expiration Date: **February 28, 2028**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com