NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016090

> 03/11/2024 **DATE:**

CERTIFICATION PROGRAM:

Fire **COMPANY: Bluelinx**

> CODE: 1366-1

EXPIRATION DATE: 03/31/2028

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Bluelinx Corporation	20 Minute Positive Pressure
225 Collins Road	Molded Simulated Panel Side-Hinged
Elkhart, IN 46516	Side-Hinged Door Assembly
	Manufacturer Specific Fire Doors for Single Swing or Standard Pairs Installation in 20 Minute Locations
	1/2" Minimum Latch Throw Single Swing or Standard Pairs Only
	Single Swing Maximum Size: 3'0" x 8'0" Standard Pairs Maximum Size: 6'0" x 8'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (1999) UL 10(b) (2009) CAN4-S104 (1985)(2010) UL 10(c) (2009)	20 Minute-Positive Pressure With Hose Stream Category B Door-Additional Edge Seal Required
	For Use in Category C Frame (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT

Intertek Test Report No: 3192291COQ-005, 100211525COQ-001, 100553244COQ-002, 100581395MID-001, 101432263COQ

NAMI Waiver of Retest: W-2063/W-2090

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway **Hayes, VA 23072** Tel: (804) 684-5124/nami@namiinc.com

NOPC-03/30/2023