

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016091
DATE: 03/11/2024
CERTIFICATION PROGRAM: Fire
COMPANY: Bluelinx
CODE: 1366-1
EXPIRATION DATE: 03/31/2028

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Bluelinx Corporation 225 Collins Road Elkhart, IN 46516	Jeld Wen 20 Minute Neutral Pressure Steel Side-Hinged Door Assembly Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Single Swing Maximum Size: 3'6" x 6'8" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2008) UL 10B (2009) UBC 7-2 (1994)	20 Minute-Neutral Pressure With Hose Stream Category B - Additional Edge Sealing Required

TEST REPORT
Intertek Test Report No: WHI 495-0897, 100108677COQ-001, 100211525COQ-001, 100237214MID-001, 100754937MID-001 NAMI Waiver of Retest: W-2090

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

**4794 George Washington Memorial Highway
Hayes, VA 23072**

**Tel: (804) 684-5124
nami@namiinc.com**

NOPC-03/30/2023