

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016102
DATE: 03/12/2024
CERTIFICATION PROGRAM: Fire
COMPANY: Bari Millwork
CODE: 3020-1
EXPIRATION DATE: 03/31/2028

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Bari Millwork & Supply, LLC 1975 Northwest 18th Street Pompano Beach, FL 33069	Jeld Wen 20 Minute Neutral Pressure Steel Side-Hinged Door Assembly Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Single Swing Maximum Size: 3'6" x 6'8" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2008) UL 10B (2009) UBC 7-2 (1994)	20 Minute-Neutral Pressure With Hose Stream Category B - Additional Edge Sealing Required

TEST REPORT
Intertek Test Report No: WHI 495-0897, 100108677COQ-001, 100211525COQ-001, 100237214MID-001, 100754937MID-001

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC-03/30/2023