

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016107.01  
DATE: 03/18/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: A Window  
CODE: 412-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>A Window, Inc.</b> <b>6201-C Dowdell Road</b> <b>Fort Worth, TX 76119</b>	<b>Series "SH31-PW"</b> <b>Vinyl Fixed Window</b>  Configuration: O Glazing: Insulating Glass (Annealed)  Frame: W-1219mm(48") H-1219mm(48") DLO: W-1149mm(45.25") H-1149mm(45.25")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b>	<b>Class LC-PG50 1219 x 1219* (48 x 48*)-FW</b> <b>Design Pressure: ±2400 Pa (±50 psf)</b> <b>Water Penetration Resistance Pressure: 360 Pa (7.52 psf)</b>

Product Tested By: Molimo, LLC  
Report No: 12242.03-109-12  
Expiration Date: March 31, 2027

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Shirley", written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)