

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016107
DATE: 03/18/2024
CERTIFICATION PROGRAM: Structural
COMPANY: A Window
CODE: 412-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
A Window, Inc. 6201-C Dowdell Road Fort Worth, TX 76119	Series "SH31-PW" Vinyl Fixed Window Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-1829mm(72") H-1829mm(72") DLO: W-1759mm(69.25") H-1759mm(69.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11	Class LC-PG50 1829 x 1829 (72 x 72)-FW Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Pressure: 360 Pa (7.52 psf)

Product Tested By: Molimo, LLC
Report No: 12242.03-109-12
Expiration Date: March 31, 2027

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com