

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016108  
DATE: 03/19/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: Willamette  
CODE: 2992-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Willamette Windows Corporation</b> <b>2800 Pringle Road SE, Suite 120</b> <b>Salem, OR 97209</b>	<b>Series "Santiam"</b> <b>Vinyl Horizontal Sliding Window</b>  Configuration: OX Glazing: Insulating Glass (Annealed) Frame: W-1829mm(72") H-1829mm(72") Sash: W-924mm(36.38") H-1765mm(69.50") DLO: W-838mm(33") H-1740mm(68.50")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class LC-PG35 1829 x 1829 (72 x 72)-HS</b> <b>Design Pressure: ±1680 Pa (±35 psf)</b> Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Intertek, PLC  
Report No: L0380.01-901-44  
Expiration Date: **February 28, 2028**

Administrator's Signature: \_\_\_\_\_ 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)