

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016109
DATE: 03/19/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Willamette
CODE: 2992-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| Willamette Windows Corporation 2800 Pringle Road SE, Suite 120 Salem, OR 97209 | Series "Santiam" Vinyl Single Hung Window Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1143mm(45") H-1905mm(75") Sash: W-1073mm(42.25") H-962mm(37.88") DLO: W-1048mm(41.25") H-879mm(34.63") |

| SPECIFICATION | PRODUCT RATING |
|--|---|
| AAMA/WDMA/CSA 101/I.S.2/A440-17 | Class LC-PG40 1143 x 1905 (45 x 75)-H Design Pressure: ±1920 Pa (±40 psf) Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf) Canadian Air Infiltration/Exfiltration Level: A2 |

Product Tested By: Intertek, PLC
Report No: L3036.01-901-44
Expiration Date: **February 28, 2028**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com