## NOTICE OF PRODUCT CERTIFICATION •



CERTIFICATION NO: NI016111.01

**DATE:** 03/20/2024

CERTIFICATION PROGRAM: Structural

**COMPANY:** Moss Supply

**CODE: 206-1** 

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <a href="https://www.namicertification.com">www.namicertification.com</a>. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION	
Moss Supply Company	Series "9230"	
5001 North Graham Street	Vinyl Horizontal Sliding Window	
Charlotte, NC 28269		
	Configuration: XX Glazing: Insulating Glass (Anneal	ed)
	Frame: W-1829mm(72") H-1524mm	n(60")
	Vent: W-899mm(35.38") H-1448mm	(57")
	DLO: W-829mm(32.63") H-1372mm	n(54")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22	Class R-PG20 1829 x 1524 (72 x 60)-HS
	Design Pressure: ±720 Pa (±15 psf)
	Water Penetration Resistance Test Pressure: 180 Pa (3.76 psf)

Product Tested By: Intertek, PLC

Report No: Q2271.01-109-44 (Specimen 2)

Expiration Date: August 31, 2027

Administrator's Signature:

Shi

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072

Tel: (804) 684-5124 Email: <a href="mailto:nami@namiinc.com">nami@namiinc.com</a>

NOPC-03/30/2023