

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016111.03
DATE: 03/20/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Moss Supply
CODE: 206-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|--|
| Moss Supply Company 5001 North Graham Street Charlotte, NC 28269 | Series "9230" Vinyl Horizontal Sliding Window Configuration: XX Glazing: Insulating Glass (Annealed) Frame: W-1600mm(63") H-1118mm(44") Vent: W-783mm(30.81") H-1045mm(41.13") DLO: W-708mm(27.88") H-965mm(38") |

| SPECIFICATION | PRODUCT RATING |
|--|--|
| AAMA/WDMA/CSA 101/I.S.2/A440-22 | Class R-PG25 1600 x 1118* (63 x 44*)-HS Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test Pressure: 180 Pa (3.76 psf) |

Product Tested By: Intertek, PLC
Report No: Q2271.01-109-44 (Specimen 4)
Expiration Date: August 31, 2027

Administrator's Signature:  _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com