

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014013-R2
DATE: 04/04/2018
CERTIFICATION PROGRAM: Fire
COMPANY: Gator Build Sup
CODE: 2152-1
REVISION DATE: 03/17/2026
EXPIRATION DATE: 04/30/2029

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Gator Building Supply, Inc. 9555 North US 1 Sebastian, FL 32958	Therma-Tru20 Minute SmoothStar Fiberglass Door w/Proprietary Core (Simulated Panel Type or Flush) Manufacture Specific Fire Door Frames for Single Swing Installation in 20 Minute Locations Single Door Maximum Size: 3'0" x 8'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
UL 10C (2009)(R2015) NFPA 252 (2012)	20 Minute-without Hose Stream Positive Pressure Category B- Additional Edge Sealing Required

TEST REPORT

Intertek Test Report No: 3033943, 3084465, 3176111MID-002,
3187023MID-002, 100354358MID-001, 100537989MID-001 & 102613119MID-004

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com

NOPC-03/30/2023