

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014779.11  
DATE: 04/17/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: Intus  
CODE: 1817-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Intus Windows, LLC</b> <b>2720 Prosperity Avenue, 400-1</b> <b>Fairfax, VA 22031</b>	<b>Series "Supera"</b> <b>Polymer Fixed Windows</b>  Configuration: 000/00 Glazing: Insulating Glass (Tempered)  Frame: W-4890mm(192.50") H-3048mm(120") Lite #3: W-2489mm(98") H-1500mm(59.06") DLO #3: W-2330mm(91.75") H-1383mm(54.44")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class CW-PG55 4890 x 3048 (193 x 120)-FW</b> <b>Design Pressure: ±2640 Pa (±55 psf)</b> <b>Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)</b>

Product Tested By: Molimo Architectural Product Testing  
Report No: 12199.03-106-11/W-2118  
Expiration Date: **December 31, 2027**

Administrator's Signature:  \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)