

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015838.02  
**DATE:** 04/03/2024  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Intus  
**CODE:** 1817-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Intus Windows, LLC</b> <b>2720 Prosperity Avenue, 400-1</b> <b>Fairfax, VA 22031</b>	<b>Series "Supera"</b> <b>Polymer Outswing Side Hinged Door</b>  Configuration: X  Glazing: IG-Ext. 5/32" Annealed Glass/0.090" Sentryglas SG5000 Interlayer/ 5/32" Annealed Glass/Int. 1/4" Tempered Glass  Frame: W-1197mm(47.13") H-2197mm(86.50")  Panel: W-1092mm(43") H-2130mm(83.88")  DLO: W-876mm(34.50") H-1915mm(75.38")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>ASTM E1886-19</b> <b>ASTM E1996-20</b> <b>TAS 201/202/203-94</b>	<b>Class CW-PG70 1197 x 2197 (47 x 87)-SHD</b> <b>Design Pressure: ±3360 Pa (±70 psf)</b> <b>Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)</b> <b>Wind Zone 4 - Missile Level D</b> <b>Large Missile Impact Rated</b>

Product Tested By: Molimo Architectural Product Testing  
Report No: 28333.01-106-13/28333.02-106-13/28333.03-106-11  
Expiration Date: March 31, 2028

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "MD", written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023