

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015870.05  
**DATE:** 04/29/2024  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** ABI Windows  
**CODE:** 2942-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>ABI Windows, LLC</b> <b>1121 Fulwiler Road</b> <b>Abilene, Texas 79603</b>	<b>Series "500"</b> <b>Vinyl Fixed- Single Hung-Fixed Window</b>  Configuration: OO/XO Glazing: Insulating Glass (Annealed) Frame: W-2743mm(107.99") H-1829mm(72.01") Sash: W-826mm(32.50") H-883mm(34.75") DLO: W-759mm(29.88") H-813mm(32")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class R-PG35 2743 x 1829 (108 x 72)-FW/H</b> <b>Design Pressure: ±1680 Pa (±35 psf)</b> Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)

Product Tested By: Construction Consulting Laboratory  
Report No: CCL 24-039  
Expiration Date: December 31, 2027

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)