

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015870.07
DATE: 04/30/2024
CERTIFICATION PROGRAM: Structural
COMPANY: ABI Windows
CODE: 2942-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ABI Windows, LLC 1121 Fulwiler Road Abilene, Texas 79603	Series "500" Vinyl Single Hung Window (w/Transom) Configuration: O/O/X Glazing: Insulating Glass (Annealed) Frame: W-1219mm(48") H-2750mm(108.25") Sash: W-1156mm(45.50") H-1041mm(41") DLO: W-1073mm(42.25") H-972mm(38.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class LC-PG35 1219 x 2750 (48 x 108)-H Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)

Product Tested By: Construction Consulting Laboratory
Report No: CCL 24-066/2602T0004
Expiration Date: **January 31, 2028**

Administrator's Signature: _____ 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com