NOTICE OF PRODUCT CERTIFICATION •



CERTIFICATION NO: NI016109.01

DATE: 03/25/2024

CERTIFICATION PROGRAM: <u>Structural</u>

COMPANY: Willamette

CODE: <u>2992-1</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Willamette Windows Corporation	Series "Santiam"
2800 Pringle Road SE, Suite 120	Vinyl Single Hung Window
Salem, OR 97209	(w/Fixed Window)
	Configuration: O/XO Glazing: Insulating Glass (Tempered)
	Frame: W-1829mm(72") H-1981mm(78")
	Sash: W-838mm(33") H-1000mm(39.38")
	DLO: W-743mm(29.25") H-905mm(35.63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22	Class LC-PG35 1829 x 1981 (72 x 78)-H
	Design Pressure: ±1680 Pa (±35 psf)
	Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)
	Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Intertek, PLC

Report No: Q6713.01-901-44/L3036.01-901-44

Expiration Date: February 28, 2028

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072

> Tel: (804) 684-5124 Email: nami@namiinc.com