

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI016113  
**DATE:** 04/01/2024  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Moss  
**CODE:** 206-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Moss Supply Company</b> <b>5001 North Graham Street</b> <b>Charlotte, NC 28269</b>	<b>Series "3700 Rep/3800 NC/3805 NC no J"</b> <b>Vinyl Outswing Awning Window</b> (Replacement or New Construction Frame)  Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-1245mm(49") H-813mm(32") Vent: W-1168mm(46") H-762mm(30") DLO: W-1057mm(41.63") H-651mm(25.63")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b>	<b>Class LC-PG50 1245 x 813 (49 x 32)-AP</b> <b>Design Pressure: ±2400 Pa (±50 psf)</b> Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Molimo, LLC  
Report No: 27163.05-109-11  
Expiration Date: October 31, 2027

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'MD'.

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)