

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016119
DATE: 04/04/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Coeur D'Alene
CODE: 1654-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Coeur D'Alene Window Company, LLC 115 N. Sycamore Street Spokane, WA 99202	Series "4722" Vinyl Horizontal Sliding Window Configuration: XX Glazing: Insulating Glass (Annealed) Frame: W-1829mm(72") H-1422mm(56") Sash: W-870mm(34.25") H-1327mm(52.25") DLO: W-787mm(31") H-1245mm(49")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class LC-PG35 1829 x 1422 (72 x 56)-HS Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Intertek, PLC
Report No: K7990.01-901-44
Expiration Date: **January 31, 2028**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com