

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016126.01  
DATE: 04/11/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: Kommerling  
CODE: 3045-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Kommerling USA, Inc.</b> <b>3402 Stanwood Blvd.</b> <b>Huntsville, AL 35811</b>	<b>Series "Profine 76 Tilt &amp; Turn"</b> <b>Vinyl Dual Action Window</b>  Configuration: X Glazing: Insulating Glass (Annealed)  Frame: W-1124mm(44.25") H-2420mm(95.28") Sash: W-1040mm(40.94") H-2335mm(91.93")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>CSA A440S1-17</b>	<b>Class R-PG60 1124 x 2420 (44 x 95)-DAW</b> <b>Design Pressure: ±2880 Pa (±60 psf)</b> Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Exova  
Report No: 18-06-B0146-4N  
Expiration Date: **March 31, 2028**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)