

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016126
DATE: 04/11/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Kommerling
CODE: 3045-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Kommerling USA, Inc. 3402 Stanwood Blvd. Huntsville, AL 35811	Series "Profine 76 Tilt & Turn" Vinyl Dual Action Window Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-1524mm(60") H-1524mm(60") Sash: W-1448mm(57.01") H-1448mm(57.01")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 CSA A440S1-17	Class LC-PG45 1524 x 1524 (60 x 60)-DAW Design Pressure: 2160 Pa (45 psf) Positive Design Pressure: 3360 Pa (70 psf) Negative Design Pressure: 3360 Pa (70 psf) Water Penetration Resistance Test Pressure: 330 Pa (6.89 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Exova
Report No: 18-06-B0146-2N
Expiration Date: March 31, 2028

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023