

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016127
DATE: 04/11/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Kommerling
CODE: 3045-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Kommerling USA, Inc. 3402 Stanwood Blvd. Huntsville, AL 35811	Series "Premidoor 76" Vinyl Sliding Glass Door Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-4585mm(180.51") H-2555mm(100.59") Panel: W-2255mm(88.78") H-2408mm(94.80")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 CSA A440S1-17	Class R-PG15 4585 x 2555 (181 x 101)-SD Design Pressure: ± 720 Pa (± 15 psf) Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Element
Report No: 18-06-B0146-7N
Expiration Date: March 31, 2028

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023