

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016132
DATE: 04/15/2024
CERTIFICATION PROGRAM: Structural
COMPANY: ABI Windows
CODE: 2942-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ABI Windows, LLC 1121 Fulwiler Road Abilene, Texas 79603	Series "600" Vinyl Sliding Glass Door (2-Lite) Configuration: OX Glazing: Insulating Glass (Tempered) Frame: W-2210mm(87") H-2108mm(83") Panel: W-1140mm(44.88") H-2038mm(80.25") DLO: W-987mm(38.88") H-1889mm(74.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class LC-PG45 2210 x 2108 (87 x 83)-SD Design Pressure: 2160 Pa (45 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 330 Pa (6.89 psf)

Product Tested By: PRI Construction Materials Technologies, LLC
Report No: 2225T0001.03
Expiration Date: April 30, 2028

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'Shi' or similar, written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com