

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016136
DATE: 04/24/2024
CERTIFICATION PROGRAM: Structural
COMPANY: VALDA 90
CODE: 2773-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
VALDA 90 OOD 5002 Western Industrial Zone Veliko Tarnovo, Bulgaria	Series "SP 68" Aluminum Sliding Glass Door Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-3100mm(122.06") H-2494mm(98.19") Panel: W-1529mm(60.19") H-2400mm(94.50") DLO: W-1426mm(56.13") H-2270mm(89.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 CSA A440S1-09	Class CW-PG60 3100 x 2494 (122 x 98)-SD Design Pressure: ±2880 Pa (±60 psf) Water Penetration Resistance Test Pressure: 430 Pa (9.00 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Intertek, PLC
Report No: K0111.03-301-47
Expiration Date: **March 31, 2028**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023