

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016139.02
DATE: 04/24/2024
CERTIFICATION PROGRAM: Structural
COMPANY: VALDA 90
CODE: 2773-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
VALDA 90 OOD 5002 Western Industrial Zone Veliko Tarnovo, Bulgaria	Series "Masterline 8" Aluminum Casement Window Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-900mm(35.43") H-1500mm(59.06") Vent: W-846mm(33.31") H-1446mm(56.93") DLO: W-654mm(25.75") H-1254mm(49.37")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class AW-PG95 900 x 1500 (35 x 59)-C Design Pressure: ±4560 Pa (±95 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: UL Laboratory Canada, Inc.
Report No: AI-05614-A2
Expiration Date: March 31, 2028

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023